



**ZEAL INTERNATIONAL** (An ISO 9001 Certified Company)

**Head Office:** 1, Netaji Subhash Marg Daryaganj, New Delhi - 110002 INDIA

Phone: +91-11-23276114, 23244474, 23250281, 23278846 Fax: +91-11-43580558

**Branch Office:** 4/20 Kirti Nagar Industrial Area New Delhi - 110015 Phone: +91 11 45380800

**Warehouse:** 4/26 Kirti Nagar Industrial Area New Delhi – 110015

[info@zealinternational.com](mailto:info@zealinternational.com)

[sales@zealinternational.com](mailto:sales@zealinternational.com)

[support@zealinternational.com](mailto:support@zealinternational.com)

[quotation@zealinternational.com](mailto:quotation@zealinternational.com)

Visit us at: [www.zealinternational.com](http://www.zealinternational.com)

## Water Meter C Type JPI 3002

Standards:

Specification:

- Meters have EEC marking.
- Hermetically sealed register (IP 68)
- High over load capacity .
- Symmetrical calibration adjustment ( DN 300 )
- Rotor Hydrodynamically balanced ( DN 300 )
- Removable measuring element .
- Powder coating offers maximum corrosion resistance .
- Register can be rotated through 360°
- Not affected by external Magnetic fields.
- ¼" connection port for pressure sensor .
- Upto 3 pulsers( 1 X OD , 2 X RD ) may be fitted without breaking the approval seal.
- Data Logger compatible meter can also be supplied.

